



NORTHPOINT



STATEMENT OF CONFORMITY 2010

This is to certify that

NORTHPOINT LTD

Will apply Fusion Bonded Epoxy Coating [FBE] to the agreed minimum dry film thickness as determined by the contract.

The applied coating is:

**DWI REGULATION 31(4)(a) APPROVED FOR
CONTACT WITH POTABLE WATER**

SPECIFICATION:

SHOTBLAST TO BS 7079 SA 2 ½ QUALITY

**MINIMUM DRY FILM THICKNESS 300 MICRONS [OR GREATER WHERE
AGREED BY CONTRACT]**

HOLIDAY FREE AT 1500v

Maximum length when suspended from a single point: 6000mm

Maximum finished weight: 4800kg

3M brand Scotchkote 206N FBE meets specification WIS 4-52-01 Pt 1

Authorised by: **Mr. P Dawson** CMIO SH MBA
Technical Director

Issue Date: 1st January 2010

Expiry Date: 31st December 2010

Northpoint Ltd
Globe Lane
Dukinfield
SK16 4UY

T: 0161 – 330 4551 F: 0161 – 339 7169
www.northpoint.ltd.uk